

INVITATION TO BID

Sealed bids will be received by the City of Clewiston at City Hall, Attention: City of Clewiston Distribution Substation Relay upgrades and Breaker replacement BID NO. 2020-09 **until Monday November 9, at 9:30 a.m.** The Bids will be opened immediately following the bid submittal deadline at City Hall.

A site visit is encouraged but not mandatory.

The project is titled City of Clewiston Distribution Substation Relay Upgrades and Breaker Replacement. The work consists of replacement of two existing low side bank breakers, replacement of differential and high-side overcurrent relays on both T1 and T2 138kV substation transformers, relocation of low side bank relays from substation yard to control house, replacement of the existing bus differential relaying and junction boxes, update of all the drawings associated with this relay/breaker upgrade, replacement of existing SCADA system and associated work.

All materials furnished and all work performed, shall be in accordance with the plans, specifications, and contract documents pertaining thereto, which may be examined at the office of the city clerk, **Clewiston City Hall, 115 W. Ventura Avenue, Clewiston, Florida 33440**. The documents, plans, and blank bid forms **may be obtained electronically by request** via e-mail at kathy.combass@clewiston-fl.gov.

A bid bond in a sum not less than five percent (5%) of the amount of the bid, made payable to the City of Clewiston, shall accompany each bid as a guarantee that the bidder will not withdraw from the competition after opening of the bids, failing which, he shall forfeit the bid deposit as liquidated damages.

The owner reserves the right to hold all bids for 180 days and to reject any and all bids, with or without cause, to waive technical errors and informalities, or to accept the bid in its judgment that serves the owner.

Randy Martin, City Manager
City of Clewiston, Florida

CITY OF CLEWISTON

ADDENDUM NO. 1

for

BID NO. 2020-09

CITY OF CLEWISTON DISTRIBUTION SUBSTATION RELAY UPGRADES AND BREAKER REPLACEMENT

ISSUE DATE: Friday, October 16, 2020

The following changes, additions, deletions and/or clarifications are made to Bid No. 2020-09.

CLARIFICATIONS

The following questions have been received from proposers to date:

1. Who do I send technical questions to? I do not see the list of equipment to be supplied by the customer or contractors.

ANSWER TO QUESTION 1: For the Substation and Civil disciplines, the 15kV circuit breaker will be supplied by the Owner for the Contractor's installation (Section 01 11 00 – 1.4A WORK BY OTHERS). All other work shall be provided and installed as described in Section 01 11 00 of the Construction Specification – or specifically defined on a Bill of Material (Section 01 11 00 1.4B WORK BY OTHERS).

2. Is the Owner supplying the ABB R-Mag circuit breakers?

ANSWER TO QUESTION 2: Yes.

No further changes, additions, deletions and/or clarifications are made to Bid No. 2020-09 in this Addendum No. 1.

Proposals for Bid No. 2020-09 will continue to be received at the City of Clewiston City Hall located at 115 West Ventura Avenue, Clewiston, FL 33440, until Monday, November 9, 2020 at 9:30 a.m. local time.